



Flowserve Gen 6 Production	
<b>Document Status</b>	Issued
<b>Document title</b>	SIL - FlowTop: V726, D726, V738, D738, V740, D740, FlowPro V724, V760, FlowAct 253, 503, 701, 1502, 3002
<b>Document Reference Number</b>	VILFCO-PROD-SIL-044
<b>Document Revision Number</b>	4
<b>Document Type</b>	Certificate
<b>Department</b>	Site Wide
<b>Area</b>	Certificates / Approval
<b>Hard Copy Locations</b>	Quality Department
<b>Issued Date</b>	10/17/2023 6:07:10 AM
<b>Document owner</b>	Grigorova, Miglena
<b>Document Co-Owner</b>	
<b>Approvers</b>	Grigorova, Miglena
<b>Periodic Review Days</b>	1000
<b>Revision comments</b>	new Certificate No 968/V 1291.02.23
<b>Document tags</b>	

# Certificate



SIL/PL  
Capability

www.tuv.com  
ID 060000000

**No.: 968/V 1291.02/23**

<b>Product tested</b>	Control Valve with FlowAct Actuator	<b>Certificate holder</b>	Flowserve Control Valves GmbH Kasernengasse 6 9500 Villach Austria
<b>Type designation</b>	FlowTop: V726, D726, V738, D738, V740, D740 FlowPro: V724, V760  FlowAct: 253, 503, 701, 1502, 3002  (Details see Revisionlist)		
<b>Codes and standards</b>	IEC 61508 Parts 1-2 and 4-7:2010		
<b>Intended application</b>	Safety Function: Move into closed position (NC) or into opened position (NO) by spring force.  The valves are suitable for use in a safety instrumented system up to SIL 2 (low demand mode). Under consideration of the minimum required hardware fault tolerance HFT = 1 for the complete final element the valves may be used up to SIL 3.		
<b>Specific requirements</b>	The instructions of the associated Installation, Operating and Safety Manual shall be considered.		

Summary of test results see back side of this certificate.

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT FSP1 V3.0:2020 in its actual version, whose results are documented in Report No. 968/V 1291.02/23 dated 2023-05-24. This certificate is valid only for products, which are identical with the product tested. Issued by the certification body accredited by DAkkS according to DIN EN ISO/IEC 17065. The accreditation is only valid for the scope listed in the annex to the accreditation certificate D-ZE-11052-02-01.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Köln, 2023-06-20

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. (FH) Wolf Rückwart

www.fs-products.com  
www.tuv.com



**Holder:** Flowserve Control Valves GmbH  
 Kasernengasse 6  
 A-9500 Villach  
 Austria

**Product tested:** *Valve-Actuator Combination*  
**Valves FlowTop**  
**(V726/D726/V738/D738/V740/D740)**  
**Valves FlowPro (V724/V760)**  
**Actuators FlowAct (253/503/701/1502/3002)**

**Results of Assessment**

Route of Assessment		$2_H / 1_S$
Type of Sub-system		Type A
Mode of Operation		Low Demand Mode
Hardware Fault Tolerance	HFT	0
Systematic Capability		<b>SC 3</b>

**Open or Close on Demand by Spring Force**

Dangerous Failure Rate	$\lambda_D$	2.74 E-07 / h	<b>274 FIT</b>
Safe Failure Rate	$\lambda_S$	1.35 E-07 / h	<b>135 FIT</b>
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	1.22 E-03	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	1.24 E-04	

Assumptions for the calculations above: DC = 0 %,  $T_1 = 1$  year, MRT = 72 h,  $\beta_{1oo2} = 10$  %

**Origin of failure rates**

The stated failure rates for low demand are the result of an FMEDA with tailored failure rates for the design and manufacturing process. Furthermore the results have been verified by qualification tests and field-feedback data.

Failure rates include failures that occur at a random point in time and are due to degradation mechanisms such as ageing. The stated failure rates do not release the end-user from collecting and evaluating application-specific reliability data.

**Systematic Capability**

The development and manufacturing process and the functional safety management applied by the manufacturer in the relevant lifecycle phases of the product have been audited and assessed as suitable for the manufacturing of products for use in applications with a maximum Safety Integrity Level of 3 (SC 3).

**Periodic Tests and Maintenance**

The given values require periodic tests and maintenance as described in the Safety Manual.

The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.

**Holder:** Flowserve Control Valves GmbH  
 Kasernengasse 6  
 A-9500 Villach  
 Austria

**Product tested:** *Valves*  
**Valves FlowTop**  
**(V726/D726/V738/D738/V740/D740)**  
**Valves FlowPro (V724/V760)**

**Results of Assessment**

Route of Assessment		$2_H / 1_S$
Type of Sub-system		Type A
Mode of Operation		Low Demand Mode
Hardware Fault Tolerance	HFT	0
Systematic Capability		<b>SC 3</b>

**Open or Close on Demand**

Dangerous Failure Rate	$\lambda_D$	1.13 E-07 / h	<b>113 FIT</b>
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	5.03 E-04	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	5.06 E-05	

Assumptions for the calculations above: DC = 0 %,  $T_1 = 1$  year, MRT = 72 h,  $\beta_{1oo2} = 10$  %

**Origin of failure rates**

The stated failure rates for low demand are the result of an FMEDA with tailored failure rates for the design and manufacturing process. Furthermore the results have been verified by qualification tests and field-feedback data.

Failure rates include failures that occur at a random point in time and are due to degradation mechanisms such as ageing. The stated failure rates do not release the end-user from collecting and evaluating application-specific reliability data.

**Systematic Capability**

The development and manufacturing process and the functional safety management applied by the manufacturer in the relevant lifecycle phases of the product have been audited and assessed as suitable for the manufacturing of products for use in applications with a maximum Safety Integrity Level of 3 (SC 3).

**Periodic Tests and Maintenance**

The given values require periodic tests and maintenance as described in the Safety Manual.

The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.

**Holder:** Flowserve Control Valves GmbH  
 Kasernengasse 6  
 A-9500 Villach  
 Austria

**Product tested:** *Pneumatic Actuator*  
**Actuators FlowAct (253/503/701/1502/3002)**

**Results of Assessment**

Route of Assessment		$2_H / 1_S$
Type of Sub-system		Type A
Mode of Operation		Low Demand Mode
Hardware Fault Tolerance	HFT	0
Systematic Capability		<b>SC 3</b>

**Move into Safe Position by Spring Force**

Dangerous Failure Rate	$\lambda_D$	1.61 E-07 / h	<b>161 FIT</b>
Safe Failure Rate	$\lambda_S$	1.35 E-07 / h	<b>135 FIT</b>
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	7.17 E-04	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	7.22 E-05	

Assumptions for the calculations above: DC = 0 %,  $T_1 = 1$  year, MRT = 72 h,  $\beta_{1oo2} = 10$  %

**Origin of failure rates**

The stated failure rates for low demand are the result of an FMEDA with tailored failure rates for the design and manufacturing process. Furthermore the results have been verified by qualification tests and field-feedback data.

Failure rates include failures that occur at a random point in time and are due to degradation mechanisms such as ageing. The stated failure rates do not release the end-user from collecting and evaluating application-specific reliability data.

**Systematic Capability**

The development and manufacturing process and the functional safety management applied by the manufacturer in the relevant lifecycle phases of the product have been audited and assessed as suitable for the manufacturing of products for use in applications with a maximum Safety Integrity Level of 3 (SC 3).

**Periodic Tests and Maintenance**

The given values require periodic tests and maintenance as described in the Safety Manual.

The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.